

Building Report to the Trustees

October 15, 2018

- Verrasso fixed three rows of lights in the children's room, installed new ballast
- Continuing HVAC problems (10/9 heat was on while hot outside)
 - Mike McGourty is using Lemar HVAC to clean the boiler and service the system
- Floors in the two conference rooms have been painted, re-carpeted, and chairs are being re-upholstered; room renovations are being paid by the Friends
- Custodians fixed small leak from a condensate pipe by tightening the connection
- Gutter still leaking outside director's office
- Meeting with BELD about security cameras on Wednesday, October 17, at 11:00 am